



Filing Receipt

Received - 2022-01-13 10:20:57 AM
Control Number - 52667
ItemNumber - 33



PHEC

**P. O. Box 1058
Marshall, TX 75671
903-935-7936
www.phec.us**

Panola Harrison Electric Cooperative

January 14, 2022

Via Electronic Filing

Filing Clerk

Public Utility Commission of Texas

1701 North Congress Avenue

Austin, Texas 78711-3326

**Re: Project No. 52667, Attestation of Compliance with HB 4150 Concerning Lake Crossings
in Texas**

To Whom It May Concern:

Panola-Harrison Electric Cooperative, Inc. (PHEC) owns and operates distribution lines above 1 kilovolt that cross Caddo Lake, a lake listed in PURA Section 38.004(b). The distribution lines crossing Caddo Lake meet applicable vertical clearance requirements established in Rule 232 of the NESC Standard ANSI (c)(2). Vertical clearance was measured most recently by PHEC's Director of Operations on January 12th, 2022. Caddo Lake is the only lake on the list that PHEC crosses with distribution lines.

The Cooperative does not own or operate any transmission lines above 60 kilovolts in the area of Caddo Lake or any other lakes listed in PURA Section 38.004(b).

Sincerely,

PANOLA-HARRISON ELECTRIC COOPERATIVE, INC.

I swear or affirm that I have personal knowledge of the facts stated in this report or am relying on people with personal knowledge, that I am competent to testify for them, and that I have the authority to submit this report on behalf of the affected entity. I further swear or affirm that all statements made in this report are true, correct and complete.

Austin Haynes
General Manager